

2025 HPL A/V RFP Questions and Responses

Questions on A/V Hardware:

Q1: Section 274116, Extron DTP2 series equipment is either discontinued or end of life, please specify replacements

A1: Please provide a current Extron equivalent or functionally comparable product that meets or exceeds the original specifications.

Questions on Timeline:

Q1: Please also let me know when installation is expected to be completed by for this project.

A1: Construction will end and anticipated opening date of Spring 2026.

Questions on Furniture:


Q1: In the HPL Studio Audio production System, please provide the make & model for the Custom Control Room desk.

A1: Halo.Ke2 https://www.argosyconsole.com/shop/halo-ke2-1928#attribute_values=27,169



Q2: In the Editing Rooms & Production Pod Room, please provide the make & model of the Table and Desk, A/R, along with quantity.

A2 **Editing rooms 111, 112, and 113:** The “table” is millwork- so more like a countertop to the full width of the walls they’re on. There is one table per room with a total of three. **Production Pod Rooms:** For the production pod rooms, this is the main table in the space: Also included is the storage for the podcast rooms.

Editing Room Table Layout:



Production Pod Room Table and Storage

	TA-03B	OCCASIONAL TABLE	KNOLL	ROCKWELL UNSCRIPTED; ROUND CAFÉ TABLE	35" DIAMETER; NATURAL OAK VENEER TOP; BLACK BROWN TEXTURED PAINT BASE, ADD ADDITIONAL GLIDES FOR WOBBLING SUPPORT
	ST-15	STORAGE FOR PODCAST ROOMS	AIS	CREDENZA WITH CABINET DOORS, 48"W, 18"D, 28" H, L PULL	MIDWEST MAPLE